



**SECTION 099123  
INTERIOR PAINTING WITH MPI**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Surface preparation.
- B. Site application of paints.
- C. Materials for back priming woodwork.
- D. Scope: Finish interior surfaces exposed to view, unless fully factory-finished and unless otherwise indicated.
  - 1. Both sides and edges of plywood backboards for electrical and telecom equipment before installing equipment.
  - 2. Elevator pit ladders.
  - 3. Surfaces inside cabinets.
  - 4. Prime surfaces to receive wall coverings.
  - 5. Exposed walls and bottom of swimming pools and fountains.
  - 6. Mechanical and Electrical:
    - a. In finished areas, paint insulated and exposed pipes, conduit, boxes, insulated and exposed ducts, hangers, brackets, collars and supports, mechanical equipment, and electrical equipment, unless otherwise indicated.
    - b. In finished areas, paint shop-primed items.
    - c. Paint interior surfaces of air ducts and convector and baseboard heating cabinets that are visible through grilles and louvres with one coat of flat black paint to visible surfaces.
    - d. Paint dampers exposed behind louvres, grilles, and convector and baseboard cabinets to match face panels.
- E. Do Not Paint or Finish the Following Items:
  - 1. Items factory-finished unless otherwise indicated; materials and products having factory-applied primers are not considered factory-finished.
  - 2. Items indicated to receive other finishes.
  - 3. Items indicated to remain unfinished.
  - 4. Fire-rating labels, equipment serial number and capacity labels, bar code labels, and operating parts of equipment.
  - 5. Stainless steel, anodized aluminum, bronze, terne-coated stainless steel, and lead items.
  - 6. Marble, granite, slate, and other natural stones.
  - 7. Floors, unless specifically indicated.
  - 8. Ceramic and other tiles.
  - 9. Brick, architectural concrete, cast stone, integrally-coloured plaster and stucco.
  - 10. Glass.
  - 11. Concrete masonry units in utility, mechanical, and electrical spaces.
  - 12. Acoustical materials, unless specifically indicated.
  - 13. Concealed pipes, ducts, and conduits.

**1.02 RELATED REQUIREMENTS**

- A. Section 016116 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 013329.02 - Sustainable Design Reporting - LEED v4.

- C. Section 055000 - Metal Fabrications: Shop-primed items.
- D. Section 055100 - Metal Stairs: Shop-primed items.
- E. Section 099113 - Exterior Painting.
- F. Section 099600 - High-Performance Coatings.
- G. Section 099725 - Mineral-Based Coatings.
- H. Section 210553 - Identification for Fire Suppression Piping and Equipment: Painted identification.
- I. Section 210553 - Identification for Fire Suppression Piping and Equipment: Colour coding scheme for items to be painted under this section.
- J. Section 220553 - Identification for Plumbing Piping and Equipment: Painted identification.
- K. Section 220553 - Identification for Plumbing Piping and Equipment: Colour coding scheme for items to be painted under this section.
- L. Section 230553 - Identification for HVAC Piping and Equipment: Painted identification.
- M. Section 230553 - Identification for HVAC Piping and Equipment: Colour coding scheme for items to be painted under this section.
- N. Section 260553 - Identification for Electrical Systems: Painted identification.
- O. Section 260553 - Identification for Electrical Systems: Colour coding scheme for items to be painted under this section.
- P. Section 321723.13 - Painted Pavement Markings: Painted pavement markings.
- Q. Section 331600 - Water Utility Storage Tanks: Painting inside and outside of tanks.

### **1.03 DEFINITIONS**

- A. Comply with ASTM D16 for interpretation of terms used in this section.

### **1.04 REFERENCE STANDARDS**

- A. ASTM D16 - Standard Terminology for Paint, Related Coatings, Materials, and Applications 2019.
- B. ASTM D4258 - Standard Practice for Surface Cleaning Concrete for Coating 2005 (Reapproved 2017).
- C. ASTM D4259 - Standard Practice for Preparation of Concrete by Abrasion Prior to Coating Application 2018.
- D. ASTM D4260 - Standard Practice for Liquid and Gelled Acid Etching of Concrete 2005 (Reapproved 2017).
- E. ASTM D4442 - Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials 2020.
- F. MPI (APL) - Master Painters Institute Approved Products List, Master Painters and Decorators Association Current Edition.
- G. MPI (APSM) - Master Painters Institute Architectural Painting Specification Manual Current Edition.
- H. SSPC V1 (PM1) - Good Painting Practice: Painting Manual, Volume 1 2016.
- I. SSPC V2 (PM2) - Systems and Specifications: Steel Structures Painting Manual, Volume 2 2015.
- J. SSPC-SP 1 - Solvent Cleaning 2015, with Editorial Revision (2016).
- K. SSPC-SP 2 - Hand Tool Cleaning 1982, with Editorial Revision (2004).
- L. SSPC-SP 3 - Power Tool Cleaning 1982, with Editorial Revision (2004).
- M. SSPC-SP 6 - Commercial Blast Cleaning 2007.

N. SSPC-SP 13 - Surface Preparation of Concrete 1997 (Reaffirmed 2003).

### 1.05 SUBMITTALS

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide complete list of products to be used, with the following information for each:
  - 1. Manufacturer's name, product name and/or catalog number, and general product category (e.g. "alkyd enamel").
  - 2. MPI product number (e.g. MPI 47).
  - 3. Cross-reference to specified paint system(s) product is to be used in; include description of each system.
  - 4. Manufacturer's installation instructions.
  - 5. If proposal of substitutions is allowed under submittal procedures, explanation of substitutions proposed.
- C. Samples: Submit three paper "draw down" samples, 216 by 279 mm in size, illustrating range of colours available for each finishing product specified.
  - 1. Where sheen is specified, submit samples in only that sheen.
  - 2. Where sheen is not specified, submit each colour in each sheen available.
  - 3. Where sheen is not specified, discuss sheen options with consultant before preparing samples, to eliminate sheens not required.
  - 4. Allow 30 days for approval process, after receipt of complete samples by consultant.
  - 5. Paint colour submittals will not be considered until colour submittals for major materials not to be painted, such as masonry, have been approved.
- D. Samples: Submit two paper chip samples, \_\_\_\_x\_\_\_\_ mm in size illustrating range of colours and textures available for each surface finishing product scheduled.
- E. Samples: Submit two painted samples, illustrating selected colours and textures for each colour and system selected with specified coats cascaded. Submit on aluminum, \_\_\_\_x\_\_\_\_ mm in size.
- F. Certification: By manufacturer that paints, and finishes comply with VOC limits specified.
- G. Manufacturer's Instructions: Indicate special surface preparation procedures.
- H. Maintenance Data: Submit data including finish schedule showing where each product/colour/finish was used, product technical data sheets, safety data sheets (SDS), care and cleaning instructions, touch-up procedures, repair of painted and finished surfaces, and colour samples of each colour and finish used.
- I. Maintenance Materials: Supply the following for Owner's use in maintenance of project.
  - 1. See Section 016000 - Product Requirements for additional provisions.
  - 2. Extra Paint and Finish Materials: four (4), 4 L of each colour; from the same product run, store where directed.
  - 3. Label each container with colour in addition to the manufacturer's label.

### 1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified, with minimum three years documented experience.
- B. Applicator Qualifications: Company specializing in performing the type of work specified with minimum [\_\_\_\_\_] years' experience and approved by manufacturer.

### 1.07 MOCK-UP

- A. See Section 014000 - Quality Requirements for general requirements for mock-up.
- B. Provide panel, [\_\_\_\_\_] m long by [\_\_\_\_\_] m wide, illustrating paint colour, texture, and finish.
- C. Provide door and frame assembly illustrating paint colour, texture, and finish.
- D. Locate where directed by consultant.

- E. Mock-up may remain as part of the work.

#### **1.08 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.
- B. Container Label: Include manufacturer's name, type of paint, brand name, lot number, brand code, coverage, surface preparation, drying time, cleanup requirements, colour designation, and instructions for mixing and reducing.
- C. Paint Materials: Store at minimum ambient temperature of 7 degrees C and a maximum of 32 degrees C, in ventilated area, and as required by manufacturer's instructions.

#### **1.09 SITE CONDITIONS**

- A. Do not apply materials when surface and ambient temperatures are outside the temperature ranges required by the paint product manufacturer.
- B. Follow manufacturer's recommended procedures for producing best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.
- C. Do not apply materials when relative humidity exceeds 85 percent; at temperatures less than 3 degrees C above the dew point; or to damp or wet surfaces.
- D. Minimum Application Temperature for Paints: 10 degrees C for interiors unless required otherwise by manufacturer's instructions.
- E. Provide lighting level of 860 lx measured mid-height at substrate surface.

### **PART 2 PRODUCTS**

#### **2.01 MANUFACTURERS**

- A. Provide paints and finishes used in any individual system from the same manufacturer, no exceptions.
- B. Provide paints and finishes used in any individual system from the same manufacturer to the greatest extent possible.
  - 1. If a single manufacturer cannot provide specified products, minor exceptions will be permitted provided approval by consultant is obtained using the specified procedures for substitutions.
  - 2. Substitution of MPI-approved products by a different manufacturer is preferred over substitution of unapproved products by the same manufacturer.
  - 3. Substitution of other products by the same manufacturer is preferred over substitution of products by a different manufacturer.
  - 4. Substitution of a different paint system using MPI-approved products by the same manufacturer will be considered.
- C. Paints:
  - 1. Dulux Paints:
- D. Primer Sealers: Same manufacturer as topcoats.
- E. Substitutions: See Section 016000 - Product Requirements.

#### **2.02 PAINTS AND FINISHES - GENERAL**

- A. Paints and Finishes: Ready mixed, unless intended to be a site-catalyzed paint.
  - 1. Where MPI paint numbers are specified, provide products listed in the MPI (APL) for specified MPI categories.
  - 2. Where MPI paint numbers are specified, provide products listed in the MPI (APL) for specified MPI categories or non-MPI-approved products approved by the Consultant as suitable for use in the specified MPI system.
  - 3. Provide paints and finishes of a soft paste consistency, capable of being readily and uniformly dispersed to a homogeneous coating, with good flow and brushing properties, and capable of drying or curing free of streaks or sags.

4. Provide materials that are compatible with one another, and the substrates indicated under conditions of service and application, as demonstrated by manufacturer based on testing and site experience.
  5. For opaque finishes, tint each coat including primer coat and intermediate coats, one-half shade lighter than succeeding coat, with final finish coat as base colour.
  6. Supply each paint material in quantity required to complete entire project's work from a single production run.
  7. Do not reduce, thin, or dilute paint or finishes or add materials unless such procedure is specifically described in manufacturer's product instructions.
- B. Volatile Organic Compound (VOC) Content: Comply with Section 016116.
- C. Volatile Organic Compound (VOC) Content:
1. Provide paints and finishes that comply with the most stringent requirements specified in the following:
    - a. Architectural coatings VOC limits of Province in which the project is located.
    - b. CaGBC LEED Rating System, edition as stated in 013329.02; for interior wall and ceiling finish (all coats), anti-corrosive paints on interior ferrous metal, sanding sealers, other sealers, and floor coatings.
- D. Flammability: Comply with applicable code for surface burning characteristics.
- E. Sheens: Provide the sheens specified; where sheen is not specified, sheen will be selected later by consultant from the manufacturer's full line.
- F. Colours: As indicated on Drawings.
1. Selection to be made by consultant after award of contract.
  2. Allow for minimum of three colours for each system, unless otherwise indicated, without additional cost to Owner.
  3. Extend colours to surface edges; colours may change at any edge as directed by consultant.
  4. In finished areas, finish pipes, ducts, conduit, and equipment the same colour as the wall/ceiling they are mounted on/under.
  5. In utility areas, finish equipment, piping, conduit, and exposed duct work in colours according to the colour coding scheme indicated.

### 2.03 PAINT SYSTEMS - INTERIOR

- A. INT 3.1A - Latex over Water-Based Alkali-Resistant Primer.
1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), G5-Semi-Gloss (MPI 54), and G6-Gloss (MPI 114).
  2. Primer: MPI 3.
  3. Products:
    - a. Dulux Gripper Universal Acrylic Primer-Sealer 60000A (MPI 3):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
    - j. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
    - k. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
    - l. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
    - m. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
    - n. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
    - o. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):

- p. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
  - q. Glidden Ultra Interior Latex 94800, Semi-Gloss:
  - r. Glidden Ultra Interior Latex 1010, Gloss:
  - s. Glidden Ultra Interior Latex 1000, High-Gloss:
- B. INT 3.1B - Latex over Latex Aggregate.
1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), G5-Semi-Gloss (MPI 54), and G6-Gloss (MPI 114).
  2. Primer: MPI 42.
  3. Products:
    - a. PPG Perma-Crete 100% Acrylic Texture Coating 4-50C (MPI 42):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
    - j. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
    - k. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
    - l. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
    - m. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
    - n. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
    - o. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
    - p. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
    - q. Glidden Ultra Interior Latex 94800, Semi-Gloss:
    - r. Glidden Ultra Interior Latex 1010, Gloss:
    - s. Glidden Ultra Interior Latex 1000, High-Gloss:
- C. INT 3.1C - High-Performance Architectural Latex over Water-Based Alkali-Resistant Primer.
1. Gloss Level: G1-Matte or Flat (MPI 142), G2-Velvet (MPI 138), G3-Eggshell (MPI 139), G4-Satin (MPI 140), and G5-Semi-Gloss (MPI 141).
  2. Primer: MPI 3.
  3. Products:
    - a. Dulux Gripper Universal Acrylic Primer-Sealer 60000A (MPI 3):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 142):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 138):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 139):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 141):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 142):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 138):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 139):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 141):
    - j. PPG Break-Through! WB Acrylic V52-410C, Satin:
- D. INT 3.1L - Water-Based Light Industrial Coating over Water-Based Alkali-Resistant Primer.
1. Gloss Level: G3-Eggshell (MPI 151), G5-Semi-Gloss (MPI 153), and G6-Gloss (MPI 154).
  2. Primer: MPI 3.
  3. Products:
    - a. Dulux Gripper Universal Acrylic Primer-Sealer 60000A (MPI 3):
    - b. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 151):
    - c. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 153):
    - d. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-310C, Eggshell (MPI 151):

- e. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-510C, Semi-Gloss (MPI 153):
  - f. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1710C, Satin (MPI 151):
  - g. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1610C, Semi-Gloss (MPI 153):
  - h. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1510C, Gloss (MPI 154):
- E. INT 3.1M - Institutional Low Odour/Low VOC over Low Odour/Low VOC Primer Sealer.
- 1. Gloss Level: G1-Matte or Flat (MPI 143), G2-Velvet (MPI 144), G3-Eggshell (MPI 145), G4-Satin (MPI 146), G5-Semi-Gloss (MPI 147), and G6-Gloss (MPI 148).
  - 2. Primer: MPI 149.
  - 3. Products:
    - a. Dulux Lifemaster Interior Acrylic Primer/Sealer 59113 (MPI 149):
    - b. Dulux Ultra Interior Latex Primer/Sealer 976000 (MPI 149):
    - c. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 143):
    - d. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 143):
    - e. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 144):
    - f. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 145):
    - g. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 147):
- F. INT 3.2E - Concrete Stain.
- 1. Products:
    - a. PPG Perma-Crete Color Seal WB Acrylic Concrete Stain 4-4210XIC:
- G. INT 4.2A - Latex over Latex Block Filler.
- 1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), G5-Semi-Gloss (MPI 54), and G6-Gloss (MPI 114).
  - 2. Block Filler MPI 4: One coat, worked into concrete block pores.
  - 3. Products:
    - a. Dulux X-pert Interior/Exterior Block Filler 36250 (MPI 4):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
    - j. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
    - k. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
    - l. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
    - m. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
    - n. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
    - o. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
    - p. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
    - q. Glidden Ultra Interior Latex 94800, Semi-Gloss:
    - r. Glidden Ultra Interior Latex 1010, Gloss:
    - s. Glidden Ultra Interior Latex 1000, High-Gloss:
- H. INT 4.2B - Latex Aggregate.
- 1. Gloss Level: Flat (MPI 42) and Non-flat (MPI 41).
  - 2. Products:
    - a. PPG Perma-Crete 100% Acrylic Texture Coating 4-50C (MPI 42):
- I. INT 4.2D - High-Performance Architectural Latex over Latex Block Filler.
- 1. Gloss Level: G1-Matte or Flat (MPI 142), G2-Velvet (MPI 138), G3-Eggshell (MPI 139), G4-Satin (MPI 140), and G5-Semi-Gloss (MPI 141).

2. Block Filler MPI 4: One coat, worked into concrete block pores.
  3. Products:
    - a. Dulux X-pert Interior/Exterior Block Filler 36250 (MPI 4):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 142):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 138):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 139):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 141):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 142):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 138):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 139):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 141):
    - j. PPG Break-Through! WB Acrylic V52-410C, Satin:
- J. INT 4.2E - Institutional Low Odour/Low VOC over Latex Block Filler.
1. Gloss Level: G1-Matte or Flat (MPI 143), G2-Velvet (MPI 144), G3-Eggshell (MPI 145), G4-Satin (MPI 146), G5-Semi-Gloss (MPI 147), and G6-Gloss (MPI 148).
  2. Block Filler MPI 4: One coat, worked into concrete block pores.
  3. Products:
    - a. Dulux X-pert Interior/Exterior Block Filler 36250 (MPI 4):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 143):
    - c. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 143):
    - d. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 144):
    - e. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 145):
    - f. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 147):
- K. INT 4.2K - Water-Based Light Industrial Coating over Latex Block Filler.
1. Gloss Level: G3-Eggshell (MPI 151) and G5-Semi-Gloss (MPI 153).
  2. Block Filler MPI 4: One coat, worked into concrete block pores.
  3. Products:
    - a. Dulux X-pert Interior/Exterior Block Filler 36250 (MPI 4):
    - b. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 151):
    - c. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 153):
    - d. Glidden Ultra Interior Latex 1000, High-Gloss:
    - e. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-310C, Eggshell (MPI 151):
    - f. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-510C, Semi-Gloss (MPI 153):
    - g. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1710C, Satin (MPI 151):
    - h. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1610C, Semi-Gloss (MPI 153):
    - i. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1510C, Gloss (MPI 154):
- L. INT 5.1B - Water-Based Light Industrial Coating over Water-Based Rust-Inhibitive Primer.
1. Gloss Level: G3-Eggshell (MPI 151), G5-Semi-Gloss (MPI 153), and G6-Gloss (MPI 154).
  2. Primer MPI 107: Rust-inhibitive, water-based.
  3. Products:
    - a. PPG Pitt-Tech EP DTM Industrial Primer 90-1908C (MPI 107):
    - b. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 151):
    - c. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 153):
    - d. Glidden Ultra Interior Latex 1000, High-Gloss:
    - e. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-310C, Eggshell (MPI 151):
    - f. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-510C, Semi-Gloss (MPI 153):
    - g. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1710C, Satin (MPI 151):
    - h. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1610C, Semi-Gloss (MPI 153):



- i. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1510C, Gloss (MPI 154):
- M. INT 5.1C - Water-Based, Dry-Fall, over Quick-Dry Alkyd Primer.
  - 1. Gloss Level: G1-Matte or Flat (MPI 118), G3-Eggshell (MPI 155), and G5-Semi-Gloss (MPI 226).
  - 2. Primer: MPI 76.
  - 3. Products:
    - a. PPG Speedhide Interior/Exterior Steel Primer 6-208 Series:
    - b. Dulux Spray Master Dryfall Interior 100% Acrylic Latex 10113, Flat (MPI 118):
    - c. Dulux Spray Master D.T.M. Dryfall Interior Acrylic Latex 10112, Flat (MPI 118):
    - d. Glidden Spray Master Dryfall Interior WB Acrylic Latex 10120A, Eggshell (MPI 155):
    - e. Glidden Spray Master Dryfall Interior WB Acrylic Latex 10130A, Semi-Gloss (MPI 226):
- N. INT 5.1R - High-Performance Architectural Latex over Quick-Dry Alkyd Primer.
  - 1. Gloss Level: G1-Matte or Flat (MPI 142), G2-Velvet (MPI 138), G3-Eggshell (MPI 139), G4-Satin (MPI 140), and G5-Semi-Gloss (MPI 141).
  - 2. Primer: MPI 76.
  - 3. Products:
    - a. PPG Speedhide Interior/Exterior Steel Primer 6-208 Series:
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 142):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 138):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 139):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 141):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 142):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 138):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 139):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 141):
    - j. PPG Break-Through! WB Acrylic V52-410C, Satin:
- O. INT 5.1S - Institutional Low Odour/Low VOC over Water-Based Rust-Inhibitive Primer.
  - 1. Gloss Level: G1-Matte or Flat (MPI 143), G2-Velvet (MPI 144), G3-Eggshell (MPI 145), G4-Satin (MPI 146), G5-Semi-Gloss (MPI 147), and G6-Gloss (MPI 148).
  - 2. Primer MPI 107: Rust-inhibitive, water-based.
  - 3. Products:
    - a. PPG Pitt-Tech EP DTM Industrial Primer 90-1908C (MPI 107):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 143):
    - c. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 143):
    - d. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 144):
    - e. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 145):
    - f. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 147):
- P. INT 5.3H - Water-Based Dry-Fall: For low contact/traffic areas.
  - 1. Gloss Level: G1-Matte or Flat (MPI 133), G3-Eggshell (MPI 131), and G5-Semi-Gloss (MPI 158).
  - 2. Products:
    - a. Dulux Spray Master Dryfall Interior 100% Acrylic Latex 10113, Flat (MPI 133):
    - b. Dulux Spray Master D.T.M. Dryfall Interior Acrylic Latex 10112, Flat (MPI 133):
    - c. Glidden Spray Master Dryfall Interior WB Acrylic Latex 10130A, Semi-Gloss:
- Q. INT 5.3J - Latex over Water-Based Galvanized Primer.
  - 1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), G5-Semi-Gloss (MPI 54), and G6-Gloss (MPI 114).
  - 2. Primer: MPI 134.
  - 3. Products:
    - a. PPG Pitt-Tech Plus EP WB Acrylic DTM Primer 90-1912C (MPI 134):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):

- c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
  - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
  - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
  - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
  - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
  - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
  - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
  - j. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
  - k. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
  - l. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
  - m. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
  - n. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
  - o. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
  - p. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
  - q. Glidden Ultra Interior Latex 94800, Semi-Gloss:
  - r. Glidden Ultra Interior Latex 1010, Gloss:
  - s. Glidden Ultra Interior Latex 1000, High-Gloss:
- R. INT 5.3K - Water-Based Light Industrial Coating over Water-Based Galvanized Primer.
- 1. Gloss Level: G3-Eggshell (MPI 151), G5-Semi-Gloss (MPI 153), and G6-Gloss (MPI 154).
  - 2. Primer: MPI 134.
  - 3. Products:
    - a. PPG Pitt-Tech Plus EP WB Acrylic DTM Primer 90-1912C (MPI 134):
    - b. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 151):
    - c. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 153):
    - d. Glidden Ultra Interior Latex 1000, High-Gloss:
    - e. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-310C, Eggshell (MPI 151):
    - f. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-510C, Semi-Gloss (MPI 153):
    - g. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1710C, Satin (MPI 151):
    - h. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1610C, Semi-Gloss (MPI 153):
    - i. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1510C, Gloss (MPI 154):
- S. INT 5.3M - High-Performance Architectural Latex over Water-Based Galvanized Primer.
- 1. Gloss Level: G1-Matte or Flat (MPI 142), G2-Velvet (MPI 138), G3-Eggshell (MPI 139), G4-Satin (MPI 140), and G5-Semi-Gloss (MPI 141).
  - 2. Primer: MPI 134.
  - 3. Products:
    - a. PPG Pitt-Tech Plus EP WB Acrylic DTM Primer 90-1912C (MPI 134):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 142):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 138):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 139):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 141):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 142):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 138):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 139):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 141):
    - j. PPG Break-Through! WB Acrylic V52-410C, Satin:
- T. INT 5.3N - Institutional Low Odour/Low VOC over Water-Based Galvanized Primer
- 1. Gloss Level: G1-Matte or Flat (MPI 143), G2-Velvet (MPI 144), G3-Eggshell (MPI 145), G4-Satin (MPI 146), and G5-Semi-Gloss (MPI 147).
  - 2. Primer: MPI 134
  - 3. Products:

- a. PPG Pitt-Tech Plus EP WB Acrylic DTM Primer 90-1912C (MPI 134):
  - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 143):
  - c. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 143):
  - d. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 144):
  - e. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 145):
  - f. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 147):
- U. INT 6.2A - Latex over Alkyd Primer.
- 1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), and G5-Semi-Gloss (MPI 54).
  - 2. Primer: MPI 45.
  - 3. Products:
    - a. Dulux Jammer 20000 Stain Blocking Alkyd Primer Interior/Exterior, 20000:
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
    - j. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
    - k. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
    - l. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
    - m. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
    - n. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
    - o. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
    - p. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
    - q. Glidden Ultra Interior Latex 94800, Semi-Gloss:
    - r. Glidden Ultra Interior Latex 1010, Gloss:
    - s. Glidden Ultra Interior Latex 1000, High-Gloss:
- V. INT 6.2B - High-Performance Architectural Latex over Alkyd Primer.
- 1. Gloss Level: G1-Matte or Flat (MPI 142), G2-Velvet (MPI 138), and G3-Eggshell (MPI 139).
  - 2. Primer: MPI 45.
  - 3. Products:
    - a. Dulux Jammer 20000 Stain Blocking Alkyd Primer Interior/Exterior, 20000:
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 138):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 138):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 139):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 141):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 142):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 138):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 139):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 141):
    - j. PPG Break-Through! WB Acrylic V52-410C, Satin:
- W. INT 6.2D - Latex over Latex Wood Primer.
- 1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), G5-Semi-Gloss (MPI 54), and G6-Gloss (MPI 114).
  - 2. Primer: MPI 39.
  - 3. Products:
    - a. Dulux Gripper Universal Acrylic Primer-Sealer 60000A (MPI 39):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):

- c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
  - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
  - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
  - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
  - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
  - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
  - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
  - j. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
  - k. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
  - l. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
  - m. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
  - n. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
  - o. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
  - p. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
  - q. Glidden Ultra Interior Latex 94800. Semi-Gloss:
  - r. Glidden Ultra Interior Latex 1010, Gloss:
  - s. Glidden Ultra Interior Latex 1000, High-Gloss:
- X. INT 6.2L - Institutional Low Odour/Low VOC over Latex Wood Primer.
- 1. Gloss Level: G1-Matte or Flat (MPI 143), G2-Velvet (MPI 144), G3-Eggshell (MPI 145), G4-Satin (MPI 146), G5-Semi-Gloss (MPI 147), and G6-Gloss (MPI 148).
  - 2. Primer: MPI 39.
  - 3. Products:
    - a. Dulux Gripper Universal Acrylic Primer-Sealer 60000A (MPI 39):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 143):
    - c. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 143):
    - d. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 144):
    - e. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 145):
    - f. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 147):
- Y. INT 6.3A – High-Performance Architectural Latex over Latex Wood Primer:
- 1. Gloss Level: G1-Matte or Flat (MPI 142), G2-Velvet (MPI 138), G3-Eggshell (MPI 139), G4-Satin (MPI 140), and G5-Semi-Gloss (MPI 141).
  - 2. Primer: MPI 39.
  - 3. Products:
    - a. Dulux Gripper Universal Acrylic Primer-Sealer 60000A (MPI 39):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 142):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 138):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 139):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 141):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 142):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 138):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 139):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 141):
    - j. PPG Break-Through! WB Acrylic V52-410C, Satin:
- Z. INT 6.3P - Water-Based Light Industrial Coating over Alkyd Primer Sealer.
- 1. Gloss Level: G3-Eggshell (MPI 151) and G5-Semi-Gloss (MPI 153).
  - 2. Primer: MPI 45.
  - 3. Products:
    - a. Dulux Jammer 20000 Stain Blocking Alkyd Primer Interior/Exterior, 20000:
    - b. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 151):
    - c. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 153):
    - d. Glidden Ultra Interior Latex 1000, High-Gloss:

- e. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-310C, Eggshell (MPI 151):
- f. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-510C, Semi-Gloss (MPI 153):
- g. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1710C, Satin (MPI 151):
- h. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1610C, Semi-Gloss (MPI 153):
- i. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1510C, Gloss (MPI 154):

AA. INT 6.3T - Latex over Latex Wood Primer.

- 1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), G5-Semi-Gloss (MPI 54), and G6-Gloss (MPI 114).
- 2. Primer: MPI 39.
- 3. Products:
  - a. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
  - b. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
  - c. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
  - d. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
  - e. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
  - f. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
  - g. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
  - h. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
  - i. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
  - j. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
  - k. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
  - l. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
  - m. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
  - n. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
  - o. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
  - p. Glidden Ultra Interior Latex 94800, Semi-Gloss:
  - q. Glidden Ultra Interior Latex 1010, Gloss:
  - r. Glidden Ultra Interior Latex 1000, High-Gloss:

BB. INT 6.3V - Institutional Low Odour/Low VOC over Latex Wood Primer.

- 1. Gloss Level: G1-Matte or Flat (MPI 143), G2-Velvet (MPI 144), G3-Eggshell (MPI 145), G4-Satin (MPI 146), G5-Semi-Gloss (MPI 147), and G6-Gloss (MPI 148).
- 2. Primer: MPI 39.
- 3. Products:
  - a. Dulux Gripper Universal Acrylic Primer-Sealer 60000A (MPI 39):
  - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 143):
  - c. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 143):
  - d. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 144):
  - e. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 145):
  - f. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 147):

CC. INT 6.4A - Latex over Alkyd Primer Sealer.

- 1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), G5-Semi-Gloss (MPI 54), and G6-Gloss (MPI 114).
- 2. Primer: MPI 45.
- 3. Products:
  - a. Dulux Jammer 20000 Stain Blocking Alkyd Primer Interior/Exterior, 20000:
  - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
  - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
  - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
  - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
  - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):

- g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
- h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
- i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
- j. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
- k. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
- l. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
- m. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
- n. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
- o. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
- p. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
- q. Glidden Ultra Interior Latex 94800, Semi-Gloss:
- r. Glidden Ultra Interior Latex 1010, Gloss:
- s. Glidden Ultra Interior Latex 1000, High-Gloss:

DD. INT 6.4N - Water-Based Light Industrial Coating over Alkyd Primer Sealer.

- 1. Gloss Level: G3-Eggshell (MPI 151), G5-Semi-Gloss (MPI 153), and G6-Gloss (MPI 154).
- 2. Primer: MPI 45.
- 3. Products:
  - a. Dulux Jammer 20000 Stain Blocking Alkyd Primer Interior/Exterior, 20000:
  - b. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 151):
  - c. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 153):
  - d. Glidden Ultra Interior Latex 1000, High-Gloss:
  - e. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-310C, Eggshell (MPI 151):
  - f. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-510C, Semi-Gloss (MPI 153):
  - g. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1710C, Satin (MPI 151):
  - h. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1610C, Semi-Gloss (MPI 153):
  - i. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1510C, Gloss (MPI 154):

EE. INT 6.4R - Latex over Latex Wood Primer.

- 1. Gloss Level: G5-Semi-Gloss (MPI 54) and G6-Gloss (MPI 114).
- 2. Primer: MPI 39.
- 3. Products:
  - a. Dulux Gripper Universal Acrylic Primer-Sealer 60000A (MPI 39):
  - b. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
  - c. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
  - d. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
  - e. Glidden Ultra Interior Latex 94800, Semi-Gloss:
  - f. Glidden Ultra Interior Latex 1010, Gloss:
  - g. Glidden Ultra Interior Latex 1000, High-Gloss:

FF. INT 6.4S - High-Performance Architectural Latex over Latex Wood Primer.

- 1. Gloss Level: G1-Matte or Flat (MPI 142), G2-Velvet (MPI 138), G3-Eggshell (MPI 139), G4-Satin (MPI 140), and G5-Semi-Gloss (MPI 141).
- 2. Primer: MPI 39.
- 3. Products:
  - a. Dulux Gripper Universal Acrylic Primer-Sealer 60000A (MPI 39):
  - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 142):
  - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 138):
  - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 139):
  - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 141):
  - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 142):
  - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 138):
  - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 139):

- i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 141):
  - j. PPG Break-Through! WB Acrylic V52-410C, Satin:
- GG. INT 6.4T - Institutional Low Odour/VOC over Latex Wood Primer.
  - 1. Gloss Level: G1-Matte or Flat (MPI 143), G2-Velvet (MPI 144), G3-Eggshell (MPI 145), G4-Satin (MPI 146), G5-Semi-Gloss (MPI 147), and G6-Gloss (MPI 148).
  - 2. Primer: MPI 39.
  - 3. Products:
    - a. Dulux Gripper Universal Acrylic Primer-Sealer 60000A (MPI 39):
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 143):
    - c. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 143):
    - d. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 144):
    - e. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 145):
    - f. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 147):
- HH. INT 6.8A - High-Performance Architectural Latex over Solvent-Based Bonding Primer.
  - 1. Gloss Level: G1-Matte or Flat (MPI 142), G2-Velvet (MPI 138), G3-Eggshell (MPI 139), G4-Satin (MPI 140), and G5-Semi-Gloss (MPI 141).
  - 2. Primer: MPI 69.
  - 3. Products:
    - a. Dulux Jammer 20000 Stain Blocking Alkyd Primer Interior/Exterior, 20000:
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 142):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 138):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 139):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 141):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 142):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 138):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 139):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 141):
    - j. PPG Break-Through! WB Acrylic V52-410C, Satin:
- II. INT 9.1A - Latex, Flat (MPI 53).
  - 1. Products:
    - a. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
    - b. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
    - c. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
    - d. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
- JJ. INT 9.1B - Latex over Alkyd Sealer.
  - 1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), G5-Semi-Gloss (MPI 54), and G6-Gloss (MPI 114).
  - 2. Primer: MPI 45.
  - 3. Products:
    - a. Dulux Jammer 20000 Stain Blocking Alkyd Primer Interior/Exterior, 20000:
    - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
    - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
    - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
    - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
    - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
    - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
    - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
    - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
    - j. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
    - k. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
    - l. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
    - m. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):

- n. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
- o. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
- p. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
- q. Glidden Ultra Interior Latex 94800, Semi-Gloss:
- r. Glidden Ultra Interior Latex 1010, Gloss:
- s. Glidden Ultra Interior Latex 1000, High-Gloss:

KK. INT 9.1E - Latex.

1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), and G5-Semi-Gloss (MPI 54).
2. Products:
  - a. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
  - b. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
  - c. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
  - d. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
  - e. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
  - f. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
  - g. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
  - h. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
  - i. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
  - j. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
  - k. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
  - l. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
  - m. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
  - n. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
  - o. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
  - p. Glidden Ultra Interior Latex 94800, Semi-Gloss:
  - q. Glidden Ultra Interior Latex 1010, Gloss:
  - r. Glidden Ultra Interior Latex 1000, High-Gloss:

LL. INT 9.2A - Latex over Latex Primer Sealer.

1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), and G5-Semi-Gloss (MPI 54).
2. Primer: MPI 50.
3. Products:
  - a. Dulux Lifemaster Interior Acrylic Primer/Sealer 59113 (MPI 50):
  - b. Dulux Ultra Interior Latex Primer/Sealer 976000 (MPI 50):
  - c. Glidden Ultra Interior Latex Primer 36600 (MPI 50):
  - d. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
  - e. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
  - f. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
  - g. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
  - h. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
  - i. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
  - j. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
  - k. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
  - l. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
  - m. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
  - n. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
  - o. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
  - p. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
  - q. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
  - r. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
  - s. Glidden Ultra Interior Latex 94800, Semi-Gloss:



- t. Glidden Ultra Interior Latex 1010, Gloss:
- u. Glidden Ultra Interior Latex 1000, High-Gloss:

MM. INT 9.2B - High-Performance Architectural Latex over Latex Primer Sealer.

1. Gloss Level: G1-Matte or Flat (MPI 142), G2-Velvet (MPI 138), G3-Eggshell (MPI 139), G4-Satin (MPI 140), and G5-Semi-Gloss (MPI 141).
2. Primer: MPI 50.
3. Products:
  - a. Dulux Lifemaster Interior Acrylic Primer/Sealer 59113 (MPI 50):
  - b. Dulux Ultra Interior Latex Primer/Sealer 976000 (MPI 50):
  - c. Glidden Ultra Interior Latex Primer 36600 (MPI 50):
  - d. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 142):
  - e. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 138):
  - f. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 139):
  - g. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 141):
  - h. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 142):
  - i. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 138):
  - j. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 139):
  - k. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 141):
  - l. PPG Break-Through! WB Acrylic V52-410C, Satin:

NN. INT 9.2L - Water-Based Light Industrial Coating over Latex Primer Sealer.

1. Gloss Level: G3-Eggshell (MPI 151), G5-Semi-Gloss (MPI 153), and G6-Gloss (MPI 154).
2. Primer: MPI 50.
3. Products:
  - a. Dulux Lifemaster Interior Acrylic Primer/Sealer 59113 (MPI 50):
  - b. Dulux Ultra Interior Latex Primer/Sealer 976000 (MPI 50):
  - c. Glidden Ultra Interior Latex Primer 36600 (MPI 50):
  - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 151):
  - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 153):
  - f. Glidden Ultra Interior Latex 1000, High-Gloss:
  - g. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-310C, Eggshell (MPI 151):
  - h. PPG Pitt-Glaze WB1 Interior Pre-Catalyzed WB Acrylic Epoxy 16-510C, Semi-Gloss (MPI 153):
  - i. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1710C, Satin (MPI 151):
  - j. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1610C, Semi-Gloss (MPI 153):
  - k. PPG Pitt-Tech Plus EP WB Acrylic DTM Enamel 90-1510C, Gloss (MPI 154):

OO. INT 9.2M - Institutional Low Odour/Low VOC over Low Odour/Low VOC Primer Sealer.

1. Gloss Level: G1-Matte or Flat (MPI 143), G2-Velvet (MPI 144), G3-Eggshell (MPI 145), G4-Satin (MPI 146), G5-Semi-Gloss (MPI 147), and G6-Gloss (MPI 148).
2. Primer: MPI 149.
3. Products:
  - a. Dulux Lifemaster Interior Acrylic Primer/Sealer 59113 (MPI 149):
  - b. Dulux Ultra Interior Latex Primer/Sealer 976000 (MPI 149):
  - c. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 143):
  - d. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 143):
  - e. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 144):
  - f. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 145):
  - g. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 147):

PP. INT 9.3A – Latex, Flat (MPI 53).

1. Products:
  - a. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
  - b. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):

- c. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
- d. Glidden Ultra Interior Latex 94500, Flat (MPI 53):

QQ. INT 9.3B - Latex over Alkyd Sealer.

1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), G5-Semi-Gloss (MPI 54), and G6-Gloss (MPI 114).
2. Primer: MPI 45.
3. Products:
  - a. Dulux Jammer 20000 Stain Blocking Alkyd Primer Interior/Exterior, 20000:
  - b. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
  - c. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
  - d. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
  - e. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
  - f. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
  - g. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
  - h. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
  - i. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
  - j. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
  - k. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
  - l. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
  - m. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
  - n. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
  - o. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
  - p. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
  - q. Glidden Ultra Interior Latex 94800, Semi-Gloss:
  - r. Glidden Ultra Interior Latex 1010, Gloss:
  - s. Glidden Ultra Interior Latex 1000, High-Gloss:

RR. INT 9.3D - Institutional Low Odour/VOC.

1. Gloss Level: G1-Matte or Flat (MPI 143), G2-Velvet (MPI 144), G3-Eggshell (MPI 145), G4-Satin (MPI 146), G5-Semi-Gloss (MPI 147), and G6-Gloss (MPI 148).
2. Products:
  - a. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 143):
  - b. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 143):
  - c. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 144):
  - d. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 145):
  - e. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 147):

SS. INT 9.3E - High-Performance Architectural Latex.

1. Gloss Level: G1-Matte or Flat (MPI 142), G2-Velvet (MPI 138), G3-Eggshell (MPI 139), G4-Satin (MPI 140), and G5-Semi-Gloss (MPI 141).
2. Products:
  - a. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 142):
  - b. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 138):
  - c. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 139):
  - d. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 141):
  - e. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 142):
  - f. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 138):
  - g. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 139):
  - h. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 141):
  - i. PPG Break-Through! WB Acrylic V52-410C, Satin:

TT. INT 10.1A - Latex over Latex Wood Primer Sealer.

1. Gloss Level: G1-Matte or Flat (MPI 53), G2-Velvet (MPI 44), G3-Eggshell (MPI 52), G4-Satin (MPI 43), G5-Semi-Gloss (MPI 54), and G6-Gloss (MPI 114).
2. Primer: MPI 50.

3. Products:
  - a. Dulux Lifemaster Interior Acrylic Primer/Sealer 59113 (MPI 50):
  - b. Dulux Ultra Interior Latex Primer/Sealer 976000 (MPI 50):
  - c. Glidden Ultra Interior Latex Primer 36600 (MPI 50):
  - d. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 53):
  - e. Dulux Diamond Interior Acrylic Latex 15110, Eggshell (MPI 44):
  - f. Dulux Diamond Interior Acrylic Latex 14220, Pearl (MPI 52):
  - g. Dulux Diamond Interior Acrylic Latex 13210, Semi-Gloss (MPI 54):
  - h. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 53):
  - i. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 44):
  - j. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 52):
  - k. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 54):
  - l. Dulux Ultra Interior Latex 945000, Flat (MPI 53):
  - m. Dulux Ultra Interior Latex 949000, Eggshell (MPI 44):
  - n. Dulux Ultra Interior Latex 949100, Pearl (MPI 52):
  - o. Dulux Ultra Interior Latex 948000, Semi-Gloss (MPI 54):
  - p. Glidden Ultra Interior Latex 94500, Flat (MPI 53):
  - q. Glidden Ultra Interior Latex 94900, Eggshell (MPI 44):
  - r. Glidden Ultra Interior Latex 94910, Pearl (MPI 52):
  - s. Glidden Ultra Interior Latex 94800, Semi-Gloss:
  - t. Glidden Ultra Interior Latex 1010, Gloss:
  - u. Glidden Ultra Interior Latex 1000, High-Gloss:

UU. INT 10.1D - Institutional Low Odour/VOC over Latex Wood Primer Sealer.

1. Gloss Level: G1-Matte or Flat (MPI 143), G2-Velvet (MPI 144), G3-Eggshell (MPI 145), G4-Satin (MPI 146), G5-Semi-Gloss (MPI 147), and G6-Gloss (MPI 148).
2. Primer: MPI 50.
3. Products:
  - a. Dulux Lifemaster Interior Acrylic Primer/Sealer 59113 (MPI 50):
  - b. Dulux Ultra Interior Latex Primer/Sealer 976000 (MPI 50):
  - c. Glidden Ultra Interior Latex Primer 36600 (MPI 50):
  - d. Dulux Diamond Interior Acrylic Latex 12110, Flat (MPI 143):
  - e. Dulux Lifemaster Interior 100% Acrylic 59111, Flat (MPI 143):
  - f. Dulux Lifemaster Interior 100% Acrylic 59311, Eggshell (MPI 144):
  - g. Dulux Lifemaster Interior 100% Acrylic 59425, Pearl (MPI 145):
  - h. Dulux Lifemaster Interior 100% Acrylic 59211, Semi-Gloss (MPI 147):

## 2.04 ACCESSORY MATERIALS

- A. Accessory Materials: Provide primers, sealers, cleaning agents, cleaning cloths, sanding materials, and clean-up materials as required for final completion of painted surfaces.
- B. Patching Material: Latex filler.
- C. Fastener Head Cover Material: Latex filler.

## PART 3 EXECUTION

### 3.01 EXAMINATION

- A. Do not begin application of paints and finishes until substrates have been properly prepared.
- B. Verify that surfaces are ready to receive work as instructed by the product manufacturer.
- C. Examine surfaces scheduled to be finished prior to commencement of work. Report any condition that may potentially affect proper application.
- D. If substrate preparation is the responsibility of another installer, notify Consultant of unsatisfactory preparation before proceeding.
- E. Test shop-applied primer for compatibility with subsequent cover materials.

- F. Measure moisture content of surfaces using an electronic moisture meter. Do not apply finishes unless moisture content of surfaces is below the following maximums:
1. Gypsum Wallboard: 12 percent.
  2. Plaster and Stucco: 12 percent.
  3. Masonry, Concrete, and Concrete Masonry Units: 12 percent.
  4. Interior Wood: 15 percent, measured in accordance with ASTM D4442.
  5. Concrete Floors and Traffic Surfaces: 8 percent.

### 3.02 PREPARATION

- A. Clean surfaces thoroughly and correct defects prior to application.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Remove or repair existing paints or finishes that exhibit surface defects.
- D. Remove or mask surface appurtenances, including electrical plates, hardware, light fixture trim, escutcheons, and fittings, prior to preparing surfaces or finishing.
- E. Seal surfaces that might cause bleed through or staining of topcoat.
- F. Remove mildew from impervious surfaces by scrubbing with solution of tetra-sodium phosphate and bleach. Rinse with clean water and allow surface to dry.
- G. Concrete:
1. Remove release agents, curing compounds, efflorescence, and chalk. Do not coat surfaces if moisture content or alkalinity of surfaces to be coated exceeds that permitted in manufacturer's written instructions.
  2. Clean surfaces with pressurized water. Use pressure range of 10,350 to 27,580 kPa at 150 to 300 mm. Allow to dry.
  3. Clean concrete according to ASTM D4258. Allow to dry.
  4. Prepare surface as recommended by topcoat manufacturer and according to SSPC-SP 13.
- H. Masonry:
1. Remove efflorescence and chalk. Do not coat surfaces if moisture content or alkalinity of surfaces or if alkalinity of mortar joints exceed that permitted in manufacturer's written instructions. Allow to dry.
  2. Prepare surface as recommended by topcoat manufacturer.
  3. Clean surfaces with pressurized water. Use pressure range of 4,140 to 10,350 kPa at 150 to 300 mm. Allow to dry.
- I. Concrete Floors and Traffic Surfaces: Remove contamination, acid etch, and rinse floors with clear water. Verify required acid-alkali balance is achieved. Allow to dry.
- J. Gypsum Board: Fill minor defects with filler compound. Spot prime defects after repair.
- K. Plaster: Fill hairline cracks, small holes, and imperfections with latex patching plaster. Make smooth and flush with adjacent surfaces. Wash and neutralize high alkali surfaces.
- L. Insulated Coverings: Remove dirt, grease, and oil from canvas and cotton.
- M. Aluminum: Remove surface contamination and oils and wash with solvent according to SSPC-SP 1.
- N. Copper: Remove contamination by steam, high pressure water, or solvent washing.
- O. Galvanized Surfaces:
1. Remove surface contamination and oils and wash with solvent according to SSPC-SP 1.
  2. Prepare surface according to SSPC-SP 2.
- P. Ferrous Metal:
1. Solvent clean according to SSPC-SP 1.

2. Shop-Primed Surfaces: Sand and scrape to remove loose primer and rust. Feather edges to make touch-up patches inconspicuous. Clean surfaces with solvent. Prime bare steel surfaces. Re-prime entire shop-primed item.
  3. Remove rust, loose mill scale, and other foreign substances using methods recommended in writing by paint manufacturer and blast cleaning according to SSPC-SP 6 "Commercial Blast Cleaning". Protect from corrosion until coated.
- Q. Wood Surfaces to Receive Opaque Finish: Wipe off dust and grit prior to priming. Seal knots, pitch streaks, and sappy sections with sealer. Fill nail holes and cracks after primer has dried, sand between coats. Back prime concealed surfaces before installation.
- R. Glue-Laminated Beams: Prior to finishing, wash surfaces with solvent, remove grease and dirt.
- S. Wood Doors to be Site-Finished: Seal wood door top and bottom edge surfaces with tinted primer.
- T. Metal Doors to be Painted: Prime metal door top and bottom edge surfaces.

### **3.03 APPLICATION**

- A. Remove unfinished louvres, grilles, covers, and access panels on mechanical and electrical components and paint separately.
- B. Apply products in accordance with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual".
- C. Where adjacent sealant is to be painted, do not apply finish coats until sealant is applied.
- D. Do not apply finishes to surfaces that are not dry. Allow applied coats to dry before next coat is applied.
- E. Apply each coat to uniform appearance in thicknesses specified by manufacturer.
- F. Dark Colours: Regardless of number of coats specified, apply as many coats as necessary for complete hide.
- G. Sand wood and metal surfaces lightly between coats to achieve required finish.
- H. Vacuum clean surfaces of loose particles. Use tack cloth to remove dust and particles just prior to applying next coat.
- I. Reinstall electrical cover plates, hardware, light fixture trim, escutcheons, and fittings removed prior to finishing.

### **3.04 SITE QUALITY CONTROL**

- A. See Section 014000 - Quality Requirements for general requirements for site inspection.
- B. Owner will provide site inspection.
- C. Inspect and test questionable coated areas in accordance with [\_\_\_\_\_].

### **3.05 CLEANING**

- A. Collect waste material that could constitute a fire hazard, place in closed metal containers, and remove daily from site.

### **3.06 PROTECTION**

- A. Protect finishes until completion of project.
- B. Touch-up damaged finishes after Substantial Performance.

**END OF SECTION**